

We will be starting soon!

Thanks for joining us



HVAC Design For Code Officials: Reading and Understanding an ACCA Report - Manuals S, J, and D




Jennifer Rennick – In Balance Green Consulting

March 31st, 2022




Zoom Orientation

- Please be sure your full name is displayed
- Please **mute** upon joining
- Use "**Chat**" box to share questions or comments
- Under "**Participant**" select "**Raise Hand**" to share a question or comment verbally
- The session may be **recorded** and posted to 3C-REN's on-demand page. Feel free to ask questions via the chat and keep video off if you want to remain anonymous in the recording.



3C-REN: Tri-County Regional Energy Network

- Three counties working together to improve energy efficiency in the region
- Services for –
 - **Building Professionals:** industry events, training, and energy code compliance support
 - **Households:** free and discounted home upgrades
- Funded by ratepayer dollars that 3C-REN returns to the region






ENERGY
CODE
CONNECT



BUILDING
PERFORMANCE
TRAINING



HOME
ENERGY
SAVINGS



Energy Code Coach Texting Service Now Available!

- **Text the Energy Code Coach Team your questions at (805) 220-9991**
- *The Team will be responding to questions within 2 hours during normal business hours (Monday to Friday from 8 am to 5 pm).*

The logo for 3C REN Energy Code Coach, identical in design to the main logo but with 'COACH' instead of 'CONNECT'.

Text anytime, response within one business day
805-220-9991
Or submit online:
www.3c-ren.org/ecc

3C-REN Staff Online

Need help or have questions
about 3C-REN?

Send us a message!



Today's Learning Objectives

- Understand the Code requirements and the goals behind those requirements
- Know the roles and responsibilities of the Energy Consultant, Plans Examiner, HERS rater, and the HVAC Installation Contractor
- Be able to describe the main sections of an ACCA 'Report' including Manuals S, J, D, and other forms you might see
- Recognize key areas that are necessary for proper documentation and what can be done for best practices

Agenda

Right Sizing Heating, Cooling, and Air Distribution Systems in the California Building Code

ACCA Calculations in the Code...Roles and Responsibilities

Key Elements and Forms in ACCA Reports

Best Practices

Resources

Questions



Right Sizing Heating, Cooling and Air Distribution Systems in the California Building Code

Residential Heating, Cooling and Duct Design Impacts:

- Health and Welfare
- Energy Conservation
- Resource Conservation
- Occupant Comfort
- Consumer Protection




Image Credit: Mitsubishi

Heating, Cooling and Ventilation is part of the California Building Code

- California Mechanical Code Part 4
- California Energy Code Part 6
- CalGreen or California Green Building Standards Code Part 11
- All three reference the proper sizing and design of residential heating and cooling systems
- The Code allows a few methods for showing compliance:
 - ANSI/ACCA
 - ASHRAE
 - Or other approved method

Title 24 Building Standards Code

<https://www.dgs.ca.gov/BSC>

Part 1 - California Administrative Code

Part 2 - California Building Code

Part 2.5 - California Residential Code

Part 3 - California Electrical Code

Part 4 - California Mechanical Code

Part 5 - California Plumbing Code

Part 6 - California Energy Code

Part 7 - Reserved

Part 8 - California Historical Building Code

Part 9 - California Fire Code

Part 10 - California Existing Building Code

Part 11 - California Green Building Standards Code

Part 12 - California Referenced Standards Code

Part 11 Code Excerpt – Residential Mandatory Measure

Excerpt: Section 4.507 under Chapter 4 of Title 24, Part 11 CalGreen

4.507.2 Heating and air-conditioning system design.

Heating and air-conditioning systems shall be sized, designed and have their equipment selected using the following methods:

1. The **heat loss and heat gain** is established according to ANSI/ACCA 2 Manual J—2016 (*Residential Load Calculation*), ASHRAE handbooks or other equivalent design software or methods.
2. **Duct systems** are sized according to ANSI/ACCA 1 Manual D—2016 (*Residential Duct Systems*), ASHRAE handbooks or other equivalent design software or methods.
3. **Select heating and cooling equipment** according to ANSI/ACCA 3 Manual S—2014 (*Residential Equipment Selection*) or other equivalent design software or methods.



Exception: Use of alternate design temperatures necessary to ensure the systems function are acceptable.

Part 6 Energy Code reinforces the above requirement for residential design, and Part 4 Mechanical Code (314.1(2)) includes Manual B (Balancing) and (601.2) Manual D.

ANSI/ACCA Manual J, D and S

The ACCA Manuals are common method for residential loads, equipment sizing and selection, and duct design.

- American National Standards Institute (ANSI) is a non-profit testing and standards organization
- Air Conditioning Contractors of America (ACCA) is a non-profit trade association
- Manual J, S, D, etc. are registered trademarks of ACCA
- ACCA Manual J8 refers to the Eighth Edition of Manual J (MJ8)






ACCA Calculations in the Building Code... Who does what?


Roles and Responsibilities

- Many players in the process
- Different roles depend on each other; some entities play more than one role
- ACCA Methodology is a **tool set for** the tradesperson - for the HVAC designer/installer
- ACCA (or equal) is required for Residential HVAC Design
- Many Energy Consultants offer:
 - Energy Code Documentation (i.e. Title 24 Energy Reports)
 - HERS Services
 - ACCA Reports



ACCA Residential HVAC Design Process

ACCA Process



Parallel 'Title 24' –Energy Code Documentation

Appendix A Compliance Documents

Page 1

NOTE: For Documents and User Instructions, please visit our website at:
<http://energy.ca.gov/title24/2019standards>

Doc Type	Doc Category	Category Description	Document Description
CF1R's – Certificate of Compliance			
CF1R-	ADD-01-E	Additions	Prescriptive Additions Less Than 1,000 ft ²
CF1R-	ADD-02-E	Additions	Prescriptive Additions – Simple NonHERS (paper version)
CF1R-	ALT-01-E	Alterations	Prescriptive Alterations
CF1R-	ALT-02-E	Alterations	Prescriptive Alterations HVAC
CF1R-	ALT-05-E	Alterations	Prescriptive Alterations – Simple NonHERS (paper version)
CF1R-	ENV-02-E	Envelope	Area Weighted Average Calculation Worksheet
CF1R-	ENV-03-E	Envelope	Solar Heat Gain Coefficient (SHGC) Worksheet
CF1R-	ENV-04-E	Envelope	Solar Reflective Index (SRI) Worksheet
CF1R-	ENV-05-E	Envelope	Alternative Default Fenestration Procedure (NA6) Worksheet
CF1R-	ENV-06-E	Envelope	Interior and Exterior Insulation Layers Worksheet
CF1R-	NCB-01-E	Newly Constructed Buildings	Prescriptive Newly Constructed Buildings and Additions Equal to or Greater Than 1,000 ft ²
CF1R-	PLB-01-E	Plumbing (DHW)	Hydronic Heating System Worksheet
CF1R-	PRF-01-E	Performance	Residential Performance Compliance Method
CF1R-	STH-01-E	Solar Thermal	OG 100 Solar Water Heating Worksheet
CF2R's – Certificate of Installation			
CF2R-	ADD-02-E	Additions	Prescriptive Additions – Simple NonHERS (paper version)
CF2R-	ALT-05-E	Alterations	Prescriptive Alterations – Simple NonHERS (paper version)
CF2R-	ENV-01-E	Envelope-NonHERS	Fenestration Installation
CF2R-	ENV-03-E	Envelope-NonHERS	Insulation Installation
CF2R-	ENV-04-E	Envelope-NonHERS	Roofing – Radiant Barrier
CF2R-	ENV-20-H	Envelope-HERS	Building Leakage Diagnostic Test
CF2R-	ENV-21-H	Envelope-HERS	QII - Framing Stage
CF2R-	ENV-22-H	Envelope-HERS	QII – Insulation Installation Stage
CF2R-	LTG-01-E	Lighting-NonHERS	Lighting - Single Family Dwellings

2019 Residential Compliance Documents

Janu

Appendix A Compliance Documents

Page 2

Doc Type	Doc Category	Category Description	Document Description
CF2R-	LTG-02-F	Lighting-NonHERS	Lighting - Multifamily Dwellings
CF2R-	MCH-01-E	Mechanical-NonHERS	Space Conditioning Systems
CF2R-	MCH-02-E	Mechanical-NonHERS	Whole House Fan
CF2R-	MCH-04-E	Mechanical-NonHERS	Evaporative Coolers
CF2R-	MCH-20-H	Mechanical-HERS	Duct Leakage Diagnostic Test
CF2R-	MCH-21-H	Mechanical-HERS	Duct Location Verification
CF2R-	MCH-22-H	Mechanical-HERS	Fan Efficacy
CF2R-	MCH-23-H	Mechanical-HERS	Airflow Rate
CF2R-	MCH-24-H	Envelope-HERS	Building Envelope Air Leakage Worksheet
CF2R-	MCH-25-H	Mechanical-HERS	Refrigerant Charge Verification
CF2R-	MCH-26-H	Mechanical-HERS	Rated Space Conditioning System Equipment Verification
CF2R-	MCH-27-H	Mechanical-HERS	Indoor Air Quality and Mechanical Ventilation
CF2R-	MCH-28-H	Mechanical-HERS	Return Duct Design and Air Filter Grille Device Sizing According to Tables 150.0-B or C
CF2R-	MCH-29-H	Mechanical-HERS	Duct Surface Area Reduction; R-Value; Buried Ducts Compliance Credit
CF2R-	MCH-30-E	Mechanical-HERS	Ventilation cooling compliance credit
CF2R-	MCH-31-H	Mechanical-HERS	HERS Verified Whole House Fan
CF2R-	MCH-32-H	Mechanical-HERS	Kitchen Ventilation
CF2R-	PLB-01-E	Plumbing-DHW-NonHERS	Multifamily Central Hot Water System Distribution
CF2R-	PLB-02-E	Plumbing (DHW)-NonHERS	Single Dwelling Unit Hot Water System Distribution
CF2R-	PLB-03-E	Plumbing (DHW)-NonHERS	Pool and Spa Heating Systems
CF2R-	PLB-21-H	Plumbing (DHW)-HERS	HERS Verified Multifamily Central Hot Water System Distribution
CF2R-	PLB-22-H	Plumbing (DHW)-HERS	HERS Verified Single Dwelling Unit Hot Water System Distribution
CF2R-	PVB-01-E	Photovoltaics-NonHERS	Photovoltaic Systems
CF2R-	PVB-02-E	Photovoltaics-NonHERS	Battery Storage Systems
CF2R-	SRA-01-E	Solar Ready	Solar Ready Areas
CF2R-	SRA-02-E	Solar Ready	Minimum Solar Zone Area Worksheet
CF2R-	STH-01-E	Solar Thermal	Solar Water Heating Systems

2019 Residential Compliance Documents

January 2019

Appendix A Compliance Documents

Page 3

CF3R's – Certificate of Installation			
CF3R-	ENV-20-H	Envelope-HERS	Building Leakage Diagnostic Test
CF3R-	ENV-21-H	Envelope-HERS	QII - Framing Stage
CF3R-	ENV-22-H	Envelope-HERS	QII – Insulation Installation Stage
CF3R-	EXC-20-H	Existing Conditions	HERS Verification of Existing Conditions for Residential Alterations
CF3R-	MCH-20-H	Mechanical-HERS	Duct Leakage Diagnostic Test
CF3R-	MCH-21-H	Mechanical-HERS	Duct Location Verification
CF3R-	MCH-22-H	Mechanical-HERS	Fan Efficacy
CF3R-	MCH-23-H	Mechanical-HERS	Airflow Rate
CF3R-	MCH-24-H	Envelope-HERS	Building Envelope Air Leakage Worksheet
CF3R-	MCH-25-H	Mechanical-HERS	Refrigerant Charge Verification
CF3R-	MCH-26-H	Mechanical-HERS	Rated Space Conditioning System Equipment Verification
CF3R-	MCH-27-H	Mechanical-HERS	Indoor Air Quality and Mechanical Ventilation
CF3R-	MCH-28-H	Mechanical-HERS	Return Duct Design and Air Filter Device Sizing According to Tables 150.0-B or C
CF3R-	MCH-29-H	Mechanical-HERS	Duct Surface Area Reduction; R-value; Buried Ducts Compliance Credit
CF3R-	MCH-31-H	Mechanical-HERS	HERS Verified Whole House Fan
CF3R-	MCH-31-H	Mechanical-HERS	Kitchen Ventilation
CF3R-	PLB-21-H	Plumbing (DHW)-HERS	HERS Verified Multifamily Central Hot Water System Distribution
CF3R-	PLB-22-H	Plumbing (DHW)-HERS	HERS Verified High Rise Residential/Hotel/Motel Single Dwelling Unit Hot Water System Distribution
NRCV-	MCH-04-H	Mechanical-HERS	Duct Leakage Diagnostic Test
NRCV-	MCH-24-H	Mechanical-HERS	Building Envelope Air Leakage Worksheet
NRCV-	MCH-27-H	Mechanical-HERS	Indoor Air Quality and Mechanical Ventilation
NRCV-	PLB-21-H	Plumbing (DHW)-HERS	HERS Verified Multifamily Central Hot Water System Distribution
NRCV-	PLB-22-H	Plumbing (DHW)-HERS	HERS Verified High Rise Residential/Hotel/Motel Single Dwelling Unit Hot Water System Distribution

2019 Residential Compliance Documents

January 2019




What Key Elements and Forms could be in an ACCA Report?



What can you expect to see in an ACCA Report?

- General Information
 - Plans Examiner Review Form
 - Project Summary Form
- Manual J
 - J1 Forms and worksheets
 - Loads Short Form
 - Building Analysis
- Manual S
 - Manual S Compliance Form
- Manual D
 - Duct Layout / Distribution Sketch
 - Friction Rate Worksheet
 - Duct Design Summary
- Equipment Spec Sheets
 - Original Equipment Manufacture (OEM) Performance Data
 - Model /Make
 - Efficiency
 - Capacity (output) –Heating and Cooling
 - External Static Pressure and Fan (CFM) Performance Data –Blower Data



Ask for the ACCA Residential Plans Examiner Review Form



Residential Plans Examiner Review Form for HVAC System Design (Loads, Equipment, Ducts)

Form RPER 1
15 Mar 09

Contractor: Your Favorite Building Corporation
 Mechanical license:
 Building plan #: xx
 Home address (Street or Lot#, Block, Subdivision): Project Name and Location: Casa Robles example project

REQUIRED ATTACHMENTS	ATTACHED	
Manual J1 Form (and supporting worksheets) or MJ1AE Form* (and supporting worksheets):	Yes <input type="checkbox"/>	No <input type="checkbox"/>
OEM performance data (heating, cooling, blower):	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Manual D Friction Rate Worksheet:	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duct distribution sketch:	Yes <input type="checkbox"/>	No <input type="checkbox"/>

HVAC LOAD CALCULATION (IRC M1401.3)

Design Conditions

Winter Design Conditions
 Outdoor temperature: 19 °F
 Indoor temperature: 68 °F
 Total heat loss: 31103 Btuh

Summer Design Conditions
 Outdoor temperature: 102 °F
 Indoor temperature: 75 °F
 Grains difference: -19 gr/lb @ 50% RH
 Sensible heat gain: 22836 Btuh
 Latent heat gain: 906 Btuh
 Total heat gain: 23742 Btuh

Building Construction Information

Building
 Orientation: Front Door faces North
North, East, West, South, Northeast, Northwest, Southeast, Southwest
 Number of bedrooms: 3
 Conditioned floor area: 1716 ft²
 Number of occupants: 7

Windows
 Eave overhang depth: 0 ft
 Internal shade: none
Blinds, drapes, etc.
 Number of skylights: 1



HVAC EQUIPMENT SELECTION (IRC M1401.3)

Heating Equipment Data

Equipment type: Gas furnace
Furnace, Heat Pump, Boiler, etc.
 Model: Champion
 TM8E060B12MP12
 Heating output capacity: 57000 Btuh
Heat pumps - capacity at winter design outdoor conditions
 Aux. heating output capacity: 0 Btuh

Cooling Equipment Data

Equipment type: Split AC
Air conditioner, Heat pump, etc.
 Model: Champion
 TW4B3621+CM36BBCA1
 Total cooling capacity: 30460 Btuh
 Sensible cooling capacity: 24210 Btuh
 Latent cooling capacity: 6250 Btuh

Blower Data

Heating cfm: 1068
 Cooling cfm: 1167
 Static pressure: 0.50 in H2O
Fan's rated external static pressure for design airflow

HVAC DUCT DISTRIBUTION SYSTEM DESIGN (IRC M1601.1)

Design airflow: 1167 cfm
 Equipment design ESP: 0.50 in H2O
 Total device pressure losses: -0.3 in H2O
 Available static pressure (ASP): 0.20 in H2O
 Longest supply duct: 206 ft
 Longest return duct: 82 ft
 Total effective length (TEL): 287 ft
 Friction rate: 0.070 in/100ft
Friction Rate = ASP / (TEL x 100)
 Duct Materials Used
 Trunk duct: Round flex vinyl
 Branch duct: Round flex vinyl

I declare the load calculation, equipment, equipment selection and duct design were rigorously performed based on the building plan listed above. I understand the claims made on these forms will be subject to review and verification.

Contractor's printed name: _____
 Contractor's signature: _____ Date: _____

Reserved for County, Town Municipality or Authority having jurisdiction use.

*Home qualifies for MJ1AE Form based on Abridged Edition Checklist

REQUIRED ATTACHMENTS	ATTACHED	
Manual J1 Form (and supporting worksheets) or MJ1AE Form* (and supporting worksheets):	Yes <input type="checkbox"/>	No <input type="checkbox"/>
OEM performance data (heating, cooling, blower):	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Manual D Friction Rate Worksheet:	Yes <input type="checkbox"/>	No <input type="checkbox"/>
Duct distribution sketch:	Yes <input type="checkbox"/>	No <input type="checkbox"/>




Needed, but often missing:

- OEM – system performance spec sheets or cut sheets
- Friction Rate Worksheet

Manual J Load Calculation

'Load' refers to the heating and cooling capacity the mechanical equipment will need in order to meet occupant comfort. Method used to determine the size of the mechanical equipment.

- Approved computer software
- Energy/Computer Model includes:
 - Location / Climate Data
 - Building Orientation
 - Wall Assemblies
 - All windows and Skylights
 - All doors
 - Roof Assembly(s)
 - Floor/Slab Assembly(s)
 - Infiltration
 - Ventilation
 - Occupants



MJ8 and J1 Forms–What to Check?

Items to Verify	Useful Info
<ul style="list-style-type: none"> ▪ Climate / Location Data ▪ <i>Duct Location</i> ▪ <i>Building Component Orientation especially Windows</i> ▪ Windows, Skylights, Glass Doors ▪ Wall Assemblies ▪ Roof Assembly(s) ▪ Floor/Slab Assembly(s) ▪ Infiltration ▪ Ventilation ▪ Occupants / Internal Gains ▪ Solid Doors 	<ul style="list-style-type: none"> ▪ Reference Joint Appendices JA2 ▪ <i>Entirely in Conditions Space (?)</i> ▪ <i>South / West -very important</i> <i>East / North -less important</i> ▪ Code U-0.30, SHGC-0.23 ▪ 2x6 R-19 U-o.074 ▪ R-30 Attic, U-0.031 ▪ Floor R-19 U-0.037; Slab F-0.73 ▪ Semi-tight (5 ACH50) ▪ Per Title 24 and mech design ▪ Per bedroom count ▪ Code U-0.20

ITEMS TO VERIFY	
The key load elements, grouped in roughly decreasing levels of impact on the overall contribution to the loads, are:	
H I G H	<ul style="list-style-type: none"> ✓ Design Temperatures (Indoor and Outdoor) ✓ Windows, Glass Doors and Large Skylights (shading, overhangs, etc.) ✓ Ducts (location, leakage and duct wall R-values) ✓ Ceilings under an attic (R-values, roof material, roof color)
M E D I U M	<ul style="list-style-type: none"> ✓ Small Skylights ✓ Infiltration ✓ Ventilation
L O W	<ul style="list-style-type: none"> ✓ Appropriately Insulated Floors ✓ Appropriately Insulated Walls ✓ Internal Gains

Excerpted from the
ACCA Manual J Brochure

Form J1 and Worksheet

Right-J8® Form J1
Entire House
Company or Client

Job:
Date: Apr 14, 2021
By: Your Name

Looking for 'Red Flags'

- Notice the general building tree: Wall -Glazing and Orientation
- U-values look valid; match T24?
- Window areas look reasonable?
- Floor and Ceiling areas align?

Ty	Construction number	U-value (Btu/h/ft²·°F)	Or	HTM (Btu/h/ft²)		Area (ft²) or perimeter	
				Heat	Cool	Gross	Perimeter
6	W 12F-0sw	0.065	ne	2.69	0.96	1173	
	G 10D-v	0.300	ne	12.42	13.63	84	
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	8	
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	48	
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	16	
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	20	
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	20	
	W 12F-0sw	0.065	se	2.69	0.96	978	
	G 10D-v	0.300	se	12.42	13.33	49	
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	10	
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	36	
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	20	
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	28	
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	32	
	G 2 glazing, clr low-e	0.300	se	12.42	17.86	13	
	G 2 glazing, clr low-e	0.300	se	12.42	17.86	14	
	G 2 glazing, clr low-e	0.300	se	12.42	17.86	35	
	W 12F-0sw	0.065	sw	2.69	0.96	765	
	G 10D-v	0.300	sw	12.42	13.33	42	
	G 2 glazing, clr low-e	0.300	sw	12.42	16.83	6	
	G 2 glazing, clr low-e	0.300	sw	12.42	16.83	12	
	G 2 glazing, clr low-e	0.300	sw	12.42	17.86	20	
	D 11D0	0.390	sw	16.15	10.10	21	
	W 12F-0sw	0.065	nw	2.69	0.96	1029	
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	8	
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	48	
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	16	
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	20	
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	30	
	R 12C-0sw	0.091	-	3.77	1.00	459	
	D 11D0	0.390	n	16.15	10.10	21	
	C 16DR-38al	0.026	-	1.08	0.76	3156	
	F 19C-19cscp	0.049	-	0.70	0.40	798	
	F 22A-tpi	0.989	-	40.94	0.00	2242	
	F 22A-tpi	0.989	-	40.94	0.00	116	

- Windows, Skylights, Glass Doors
- Wall Assemblies
- Roof Assembly(s)
- Floor/Slab Assembly(s)

- Code U-0.30, SHGC-0.23
- 2x6 R-19 U-o.074
- R-30 Attic, U-0.031
- Floor R-19 U-0.037; Slab F-0.73

'Useful Info'

Right-J® Worksheet Entire House Company Name												Job: Date: May 24, 2021 By: Your Name			
Company Contact Information												HP-1 87.0 ft			
Room name: Entire House												1512.0 ft²			
Exposed wall: 12.4 ft												813.0 ft²			
Room height: 305.0 ft												813.0 ft²			
Room dimensions: 12.0 ft x 15.3 ft x 24.5 ft															
Room area: 316.1 ft²															
Kitchen: 39.8 ft															
12.0 ft x 15.3 ft															
heat/cool															
373.6 ft²															
Ty	Construction number	U-value (Btu/h/ft²·°F)	Or	HTM (Btu/h/ft²)		Area (ft²) or perimeter (ft)		Load (Btu/h)		Area (ft²) or perimeter (ft)		Load (Btu/h)			
				Heat	Cool	Gross	N/P/S	Heat	Cool	Gross	N/P/S	Heat	Cool		
6	W 12F-0sw	0.065	ne	2.69	0.96	1173	977	2629	934	294	240	646	229		
	G 10D-v	0.300	ne	12.42	13.63	84	0	1043	1145	42	0	522	573		
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	8	0	99	156	0	0	0	0		
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	48	0	596	935	12	0	149	234		
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	16	0	199	312	0	0	0	0		
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	20	0	248	389	0	0	0	0		
	G 2 glazing, clr low-e	0.300	ne	12.42	19.47	20	0	248	389	0	0	0	0		
	W 12F-0sw	0.065	se	2.69	0.96	978	741	1994	708	183	151	406	144		
	G 10D-v	0.300	se	12.42	13.33	49	13	609	653	0	0	0	0		
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	10	5	124	168	0	0	0	0		
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	36	16	447	606	0	0	0	0		
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	20	9	248	337	0	0	0	0		
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	28	13	348	471	0	0	0	0		
	G 2 glazing, clr low-e	0.300	se	12.42	16.83	32	15	397	538	32	15	397	538		
	G 2 glazing, clr low-e	0.300	se	12.42	17.86	13	5	160	231	0	0	0	0		
	G 2 glazing, clr low-e	0.300	se	12.42	17.86	14	5	176	253	0	0	0	0		
	G 2 glazing, clr low-e	0.300	se	12.42	17.86	35	13	436	625	0	0	0	0		
	W 12F-0sw	0.065	sw	2.69	0.96	765	664	1787	634	0	0	0	0		
	G 10D-v	0.300	sw	12.42	13.33	42	11	522	560	0	0	0	0		
	G 2 glazing, clr low-e	0.300	sw	12.42	16.83	6	3	76	101	0	0	0	0		
	G 2 glazing, clr low-e	0.300	sw	12.42	16.83	12	5	149	202	0	0	0	0		
	G 2 glazing, clr low-e	0.300	sw	12.42	17.86	20	7	248	357	0	0	0	0		
	D 11D0	0.390	sw	16.15	10.10	21	21	339	212	0	0	0	0		
	W 12F-0sw	0.065	nw	2.69	0.96	1029	907	2441	957	0	0	0	0		
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	8	0	99	156	0	0	0	0		
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	48	0	596	935	0	0	0	0		
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	16	0	199	312	0	0	0	0		
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	20	0	248	389	0	0	0	0		
	G 2 glazing, clr low-e	0.300	nw	12.42	19.47	30	0	373	584	0	0	0	0		
	R 12C-0sw	0.091	-	3.77	1.00	459	438	1650	438	0	0	0	0		
	D 11D0	0.390	n	16.15	10.10	21	21	339	212	0	0	0	0		
	C 16DR-38al	0.026	-	1.08	0.76	3156	3156	3037	2413	374	374	402	296		
	F 19C-19cscp	0.049	-	0.70	0.40	798	798	561	322	0	0	0	0		
	F 22A-tpi	0.989	-	40.94	0.00	2242	159	6510	0	374	40	1628	0		
	F 22A-tpi	0.989	-	40.94	0.00	116	20	909	0	0	0	0	0		
5 c) AED excursion												0			
Envelope loss/gain												30343 17545 4150 1817			
12 a) Infiltration												7261 2171 878 262			
b) Room ventilation												0 0 0 0			
13 Internal gains: Occupants @ 230												690 0 0 1200			
Appliances/other												2500			
Subtotal (lines 6 to 13)												37605 23005 5028 3280			
Less external load												0 0 0 0			
Less transfer												0 0 0 0			
Redistribution												0 0 0 0			
Subtotal												37605 23005 5744 3705			
14 Duct loads												41% 82% 15337 18768 41% 82% 2343 3022			
Total room load												52942 41773 8086 6727			
Air required (cfm)												1933 1933 296 311			

Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.



Load Short Form

Helpful Information:

See Climate Design Data at a glance.
 Ask, do these Outside dry bulb (db) temperatures match the location?
 Are they from the California Joint Appendices JA2?

Note: California uses inside dry bulb (db) temperature of 68 deg F for winter heating (Htg) and 75 deg F for summer cooling (Clg)

See the rooms and floor areas, and their relative load (Btuh) impact at a glance.

Company Contact Information

Project Information

For: Project Name and Location...Paso Robles
 example project

Design Information

	Htg	Clg	Method	Infiltration
Outside db (°F)	19	102	Method	Simplified
Inside db (°F)	68	75	Construction quality	Semi-tight
Design TD (°F)	49	27	Fireplaces	1 (Semi-tight)
Daily range	-	H		
Inside humidity (%)	50	50		
Moisture difference (gr/lb)	41	-19		

HEATING EQUIPMENT

Make: Champion
 Trade: CHAMPION HEATING AND COOLING
 Model: TM9E080B12MP12
 AHRI ref: 203324457

Efficiency: 95 AFUE
 Heating input: 80000 Btuh
 Heating output: 57000 Btuh
 Temperature rise: 50 °F
 Actual air flow: 1088 cfm
 Air flow factor: 0.034 cfm/Btuh
 Static pressure: 0.50 in H2O
 Space thermostat

COOLING EQUIPMENT

Make: Champion
 Trade: CHAMPION HEATING AND COOLING
 Cond: TW4B3821
 Coil: CM36BBCA1
 AHRI ref: 202694378

Efficiency: 12.2 EER, 14 SEER
 Sensible cooling: 28000 Btuh
 Latent cooling: 7000 Btuh
 Total cooling: 35000 Btuh
 Actual air flow: 1167 cfm
 Air flow factor: 0.051 cfm/Btuh
 Static pressure: 0.50 in H2O
 Load sensible heat ratio: 0.96

ROOM NAME	Area (ft²)	Htg load (Btuh)	Clg load (Btuh)	Htg AVF (cfm)	Clg AVF (cfm)
Entry	67	3183	917	109	47
M.T.	22	0	0	0	0
Lau.	72	2137	1459	73	75
Opt. Bed 3	135	1738	1928	60	99
Kitchen/Dining	446	7096	7068	244	361
Bed 2	159	2419	2123	83	109
M. Ba.	89	2758	748	95	38
Living	266	3247	2584	112	132
Bath	66	1027	604	35	31
Coat	30	0	0	0	0
Hall	99	3065	2415	105	123
M. Bed	175	4455	2992	153	153
Pan.	25	0	0	0	0
M. Clo.	66	0	0	0	0



Calculations approved by ACCA to meet all requirements of Manual J 8th Ed.

Plan XX Other equip loads	d	1716	31103	22836	1068	1167
Equip. @ 1.00 RSM			0	0		
Latent cooling				22836		
				908		
TOTALS		1716	31103	23742	1068	1167

Manual S Equipment Selection

Based on the Load Calculation from Manual J –may need refinement after the duct design process

- Use Manufacture's Data
- Adjust AHRI standard values for a dry climate; CA Joint Reference Appendices JA2 Climate Data (Title 24 Part 6)
- Heating Capacity (Output)
- Cooling Capacity (Output)
- Blower Performance Data Tables
 - External Static Pressure (ESP)
 - Fan CFM at the rated Capacity



Manual S Compliance Report

Company Contact Information

Project Information

For: Project Name and Location...Paso Robles example project

Cooling Equipment

Design Conditions

Outdoor design DB: 102°F	Sensible gain: 22836 Btuh	Entering coil DB: 75.7°F
Outdoor design WB: 67.4°F	Latent gain: 906 Btuh	Entering coil WB: 62.6°F
Indoor design DB: 75.0°F	Total gain: 23742 Btuh	
Indoor RH: 50%	Estimated airflow: 1167 cfm	

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Split AC	Model: TW4B3621+CM36BBCA1
Manufacturer: Champion	
Actual airflow: 1167 cfm	
Sensible capacity: 24210 Btuh	106% of load
Latent capacity: 6250 Btuh	690% of load
Total capacity: 30460 Btuh	128% of load SHR: 79%

Heating Equipment

Design Conditions

Outdoor design DB: 19.0°F	Heat loss: 31103 Btuh	Entering coil DB: 67.5°F
Indoor design DB: 68.0°F		

Manufacturer's Performance Data at Actual Design Conditions

Equipment type: Gas furnace	Model: TM9E060B12MP12
Manufacturer: Champion	
Actual airflow: 1068 cfm	
Output capacity: 57000 Btuh	183% of load
	Temp. rise: 50 °F

Climate Data match the location and JA2?
 Indoor Design DB (dry bulb) 75 deg F for summer?

 Does Capacity meet the load? Is it within 100 – 115%
 If not, is there a smaller unit available

 Indoor Design DB (dry bulb) 68 deg F for winter?




 Does Capacity meet the load? Is it within 100 – 140%
 If not, is there a smaller size available?
 Was the equipment sized for the blower /fan ?

Meets all requirements of ACCA Manual S.

Manual D Duct Design


Influences Energy Use and Comfort and Equipment Life

- Duct Layout Sketch
- Specialized Software is useful
- Calculates duct sizes /diameter
- Takes into account:
 - Duct layout
 - Duct material, i.e. sheet metal, flex, other
 - Duct profile / shape
 - Duct lengths
 - Connectors, Reducers, other Fittings
 - Tees and Splitter Wyes
 - Elbows -Radius or square



Duct Layout Sketch

- Basic floor plan is drawn to scale
- User chooses from a library of preferred duct and connector types for the duct system
- The user draws the preferred duct runs (branch and trucks or radial pattern, etc) and register locations
- Per length of duct, the size / diameter is calculated and called out on the plan
- The supply air volume rate (cfm –cubic feet per minute) is called out at each register
- The return air volume and register is labeled on the plan



Duct System Summary

External static pressure (ESP) comes from the Manufacture Blower Performance

Pressure losses are determined from product data

Actual air flow and Total effective length (TEL) are calculated as part of Manual D

Company Contact Information

Project Information

For: Project Name and Location...Paso Robles
example project

	Heating	Cooling
External static pressure	0.50 in H2O	0.50 in H2O
Pressure losses	0.30 in H2O	0.30 in H2O
Available static pressure	0.20 in H2O	0.20 in H2O
Supply / return available pressure	0.143 / 0.057 in H2O	0.143 / 0.057 in H2O
Lowest friction rate	0.070 in/100ft	0.070 in/100ft
Actual air flow	1068 cfm	1167 cfm
Total effective length (TEL)	287 ft	

Supply Branch Detail Table

Name	Design (Btuh)	Htg (cfm)	Clg (cfm)	Design FR	Diam (in)	H x W (in)	Duct Matl	Actual Ln (ft)	Ftg.Eqv Ln (ft)	Trunk
Bath-A	h 1027	35	31	0.079	5.0	0x0	VIFx	37.0	145.0	st5
Bed 2	c 2123	83	109	0.070	7.0	0x0	VIFx	45.7	160.0	st5
Entry-A	h 3163	109	47	0.090	7.0	0x0	VIFx	20.0	140.0	st7
Hall	c 2415	105	123	0.087	7.0	0x0	VIFx	29.6	135.0	st4
Kitchen/Dining	c 3534	122	181	0.108	10.0	0x0	VIFx	17.3	115.0	st3
Kitchen/Dining-A	c 3534	122	181	0.106	10.0	0x0	VIFx	10.2	125.0	st6
Lau-A	c 1459	73	75	0.070	5.0	0x0	VIFx	43.4	160.0	st5
Living	c 2584	112	132	0.085	7.0	0x0	VIFx	27.6	140.0	st7
M. Ba-A	h 2758	95	38	0.107	6.0	0x0	VIFx	18.5	115.0	st1
M. Bed	h 4455	153	153	0.109	8.0	0x0	VIFx	16.9	115.0	st1
Opt. Bed 3	c 1928	60	99	0.097	6.0	0x0	VIFx	32.5	115.0	st2

Supply Trunk Detail Table

Name	Trunk Type	Htg (cfm)	Clg (cfm)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Duct Material	Trunk
st2	Peak AVF	357	436	0.070	555	12.0	0 x 0	VinIFlx	
st4	Peak AVF	297	337	0.070	430	12.0	0 x 0	VinIFlx	st2
st5	Peak AVF	192	214	0.070	392	10.0	0 x 0	VinIFlx	st4
st3	Peak AVF	464	540	0.085	688	12.0	0 x 0	VinIFlx	
st6	Peak AVF	342	359	0.085	458	12.0	0 x 0	VinIFlx	st3
st7	Peak AVF	220	179	0.085	404	10.0	0 x 0	VinIFlx	st6
st1	Peak AVF	248	191	0.107	454	10.0	0 x 0	VinIFlx	

Return Branch Detail Table

Name	Grille Size (in)	Htg (cfm)	Clg (cfm)	TEL (ft)	Design FR	Veloc (fpm)	Diam (in)	H x W (in)	Stud/Joist Opening (in)	Duct Matl	Trunk
rb1	0x0	1068	1167	81.6	0.070	535	20.0	0x0		VIFx	

Heating Equipment Example

Blower Performance CFM - Any Position (without filter)

Models	Speed	Airflow Data (SCFM) ^{1,2}							
		Ext. Static Pressure (in. H ₂ O)							
		0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8
TM9E040A10MP12	High	1172	1147	1116	1083	1035	984	933	870
	Medium High	952	919	896	865	839	809	780	765
	Medium	882	861	824	802	771	746	709	685
	Medium Low	754	716	688	650	610	588	551	523
	Low	688	648	619	584	541	518	481	446
TM9E060A10MP12	High	1239	1209	1175	1143	1124	1095	1066	1019
	Medium High	1142	1102	1080	1050	1019	989	960	924
	Medium	971	935	909	869	839	805	761	731
	Medium Low	915	891	848	818	776	744	708	691
	Low	773	739	687	655	604	572	527	496
TM9E060B12MP12	High	1342	1316	1290	1268	1243	1219	1172	1116
	Medium High	1297	1267	1247	1217	1189	1159	1129	1087
	Medium	1165	1139	1108	1080	1051	1021	983	948
	Medium Low	1027	995	965	936	894	862	825	778
	Low	822	775	740	687	649	605	566	512
	High	1418	1390	1364	1333	1304	1281	1246	1205



Static Pressure and Friction Rate


Does the External Static Pressure (ESP) match the manufacture blower performance data? Range upper limit around 1.0 IWC

The equipment external static pressure (ESP) may include the coil pressure loss –read footnotes

Sometimes the equipment includes an assumed 0.10 pressure drop for air filter –read footnotes

Typical value for diffusers, grilles and balancing dampers pressure loss is 0.03 IWC

Filter loss could vary greatly...



TEL = Total Effective Length

Static Pressure and Friction Rate		Job:	
System Name		Date: Apr 14, 2021	
Example File		By: Your Name	
Company Contact Information			
Project Information			
For:	Project Name		
Available Static Pressure			
	Heating (in H2O)	Cooling (in H2O)	
External static pressure	0.20	0.20	
Pressure losses			
Coil	0		0
Heat exchanger	0		0
Supply diffusers	0.03		0.03
Return grilles	0.03		0.03
Filter	0.05		0.05
Humidifier	0		0
Balancing damper	0		0
Other device	0		0
Available static pressure	0.09		0.09
Total Effective Length			
	Supply (ft)	Return (ft)	
Measured length of run-out	13	4	
Measured length of trunk	2	0	
Equivalent length of fittings	60	30	
Total length	75	34	
Total effective length		109	
Friction Rate			
	Heating (in/100ft)	OK	Cooling (in/100ft)
Supply Ducts	0.083	OK	0.083
Return Ducts	0.083	OK	0.083
Fitting Equivalent Length Details			
Supply	4X=35, 11S=15, 1B=10: TotalEL=60		
Return	5E1=10, 6M=20: TotalEL=30		

Note: Red arrows point to the 'OK' status in the Friction Rate table and the 'OK' status in the Fitting Equivalent Length Details table.



Best Practices

Best Practices


- ✓ Use the Residential Plans Examiner Review Form
- ✓ Compare ACCA Documents to CF1R, CF2R, CF3R's
- ✓ 'Experiment' with software such as Wrightsoft Right-J and Right-D software
- ✓ Create an ACCA Checklist of your desired forms
 - Project Summary
 - J1 Form and J Worksheet
 - Manual S Summary
 - Duct Layout / Distribution
 - Duct Design Summary
 - Static Pressure and Friction Loss Worksheet
 - OEM –Manufactures Performance Data



Resources

Resources

ACCA.org –on line store and public resources



Verifying
ACCA Manual J®
Procedures

MANUAL
J
Residential Load Calculation
Hank Rutkowski, P.E.

EIGHTH EDITION

Includes demo software on CD-ROM.

ACCA
AIR CONDITIONING CONTRACTORS OF AMERICA

Includes load calculation checklist




Verifying
ACCA Manual S®
Procedures

MANUAL
S
Residential Equipment Selection

ANSI

ACCA
AIR CONDITIONING CONTRACTORS OF AMERICA

Includes Equipment Selection Checklist & Example



Verifying
ACCA Manual D®

MANUAL
D
Residential Duct Systems

ANSI

ACCA
AIR CONDITIONING CONTRACTORS OF AMERICA®

2800 Shirlington Road, Suite 300
Arlington, VA 22206
Phone 703-824-4477
Fax 703-575-4449

Includes Duct Inspection Checklist



U.S. DEPARTMENT OF ENERGY | Energy Efficiency & Renewable Energy

BUILDING TECHNOLOGIES PROGRAM

VOLUME 14. **BUILDING AMERICA BEST PRACTICES SERIES**

Energy Renovations
HVAC
A Guide for Contractors to Share with Homeowners

PREPARED BY
Pacific Northwest National Laboratory
& Oak Ridge National Laboratory

August 2011

Building America
U.S. Department of Energy

August 2011 • PBNL-20421

<https://www.acca.org/viewdocument/hvac-brochures-for-code-officials>

https://www.energy.gov/sites/default/files/2013/11/f5/hvac_guide.pdf

ACCA Manual D Brochure, page 2

Friction Rate Worksheet

Step 1) Manufacturer's Blower Data
 External Static Pressure (ESP) = 0.70 IWC CFM= 1200 CFM

Step 2) Device Pressure Losses (DPL)

Direct expansion refrigerant coil.....	0.23 IWC
Electric heat resistance coil.....	_____
Hot water coil.....	_____
Filter.....	0.18 IWC
Humidifier.....	_____
Supply outlet.....	0.03 IWC
Return grille.....	0.03 IWC
Balancing dampers.....	0.03 IWC
Other device.....	_____
Total device losses	0.50 IWC

Step 3) Available Static Pressure (ASP)
 ASP = ESP - DPL (Step 1 - Step 2) = 0.20 IWC

Step 4) Total Effective Length (TEL)
 Supply side TEL + Return side TEL = 200 ft TEL

Step 5) Friction Rate Design Value [FR=(ASPx100)=TEL] 0.10 IWC from chart below

Friction Rate Chart

Table of Useful Air Distribution System Design Information

Zone:	One	Design Friction Rate	0.10	Type of System:	Trunk and Branch
Construction Material	Supply Air Trunk	Metal		Supply Air Branch	Flex
Construction Material	Return Air Trunk	Duct board		Return Air Branch	Flex
R-Value of Insulation	Supply	R6		Return	R6
Room	Design CFM	Supply Duct Size(s)	Supply Grille(s) Size, and Velocity	Return Duct Size(s)	Return Grille Size and Velocity
Bedroom 1	150	1 - 8"	1 - 14x6, 600fpm	(9") - 12"	14x14, 300fpm
Walk-in-Closet	15	1 - 4"	1 - 8x4, 450fpm		
Bedroom 2	100	2 - 6"	2 - 10x4, 600fpm	(7") - 8"	14x8, 275fpm
Bedroom 3	100	1 - 7"	1 - 12x4, 600fpm	(7") - 8"	14x8, 275fpm
Living Room	275	2 - 8"	2 - 14x6, 575fpm	(16") - 18"	24x24, 350fpm
Den	125	1 - 8"	1 - 14x6, 600fpm		
Dining	125	2 - 6"	2 - 10x4, 600fpm		
Foyer	80	1 - 6"	1 - 10x4, 600fpm		
Bath 1	65	1 - 6"	1 - 10x4, 600fpm		
Bath 2	40	1 - 5"	1 - 8x4, 500fpm		
Bath 3					
TOTALS	1200				

Notes:
 Types of Supply System: Trunk and Branch, Perimeter Loop, Radial
 Construction Materials: Sheet metal, Fiberglass Ductboard, Rigid Round Fiberglass, Flexible Vinyl Duct, Fiberglass Duct Liner w/ Facing, Flexible Metal Duct

Recommended Velocity (FPM) (Manual D, Table 3-1)

	Supply				Return			
	Recommended		Maximum		Recommended		Maximum	
	Rigid	Flex	Rigid	Flex	Rigid	Flex	Rigid	Flex
Trunk Ducts	700	600	900	700	600	600	700	700
Branch Ducts	600	600	900	700	400	400	700	700
Supply Outlet Face Velocity	Size for Throw		700					
Return Grille Face Velocity					500			
Filter Grille Face Velocity					300			

A From manufacturer's data—equipment CFM at rated capacity

B From Manufacturer's Blower Performance Data corresponding to the CFM (#1)

C From Manufacturer's Performance Data

D Total Effective Length ≈ loss from duct lengths, reducers, elbows and other fittings

E Friction Rate is found by reading bottom scale to 0.20 and up the side scale to 200 feet the intersecting line is the 0.10. That is the design friction rate. This example, 0.10, is within the acceptable friction rate range.

F The Design CFM for each room is based on the larger of the Cooling or Heating CFM. Those heat and cool CFM come from the allocation of the system's capacity based on each room's heating and cooling needs.

G The Friction Rate is used to determine the duct size.

H The return duct size is based on the friction rate and then may be adjusted to a larger size to meet recommended velocity.

I Grille and register sizes should be selected to ensure the velocities are acceptable.

ACCA does not recommend installing return ducts in kitchens, baths, laundry, or utility rooms

ACCA Manual S Brochure, page 2

Equipment Selection Checklist			
#	Key Item	Verify	Verification Questions
1	Design Conditions	The design conditions fall within specifications.	Do the design conditions fall within the minimum standards for this region as found in Manual J8 Table 1A or 1B? (A)
		The information from the Manual J load calculation was transferred accurately.	Was the Total Heat Gain / Loss information used to evaluate equipment candidates? (B)
2	OEM's Performance Data	The equipment manufacturer's performance parameters match the design parameters used to calculate the heat load.	Does the manufacturer's performance parameters match the design parameters used to calculate the home's heat load (i.e., outdoor dry-bulb, indoor dry-bulb, and indoor wet-bulb)? If the performance data parameters are more than 5% greater or less than the design parameters then did the contractor interpolate the equipment manufacturer's performance parameters to match the design parameters used to calculate the heat load?
3	Equipment Performance	Estimated Cooling – CFM based on Temperature Difference	Was the Sensible Heat Ratio calculated? (Sensible Load / Total Load)? (C) Was the SHR used to find the proper air flow? (D)
		Equipment selected satisfies Total Btus (for cooling the Sensible and Latent load)	Is the total heating capacity of the selected equipment $\leq 140\%$ of the designed total heating load? (If not reduce equipment size) (E)
			Is the total cooling capacity of the selected equipment $\leq 115\%$ of the designed total cooling load? (If not reduce equipment size) (F)
			Does the "Sensible" and/or "Latent" capacities of the selected equipment meet the load's requirements? (G)
			If a heat pump in a very cold climate (heating is primary concern) does the total cooling capacity of the selected equipment exceed 125% of the designed total cooling load?
4	Auxiliary Heat	Heat Pump Balance Point	Does the electric auxiliary heat provide the necessary BTUs to makeup difference in capacity from the heat pump's balance point to the design load conditions? (H)

Equipment Selection using an Example Checklist													
Design			Application Data: Equipment Capacity										
Winter Design Conditions													
Outdoor °F:	27°F (A)	From Manual J8 Table 1A or 1B	A furnace was selected for comparing "heating only" design and performance. Other types of equipment may be used.										
Indoor °F:	70°F (B)	Manual J8 §3-6 defaults to 70°F	Furnace Model Number:	FU600300 (E)	Fictitious furnace								
Total Calculated Heat Loss	50,981Btu/h	Determined by Manual J8 load calculation	Output BTUH:	52,000Btu/h	Furnace Btu/h Output: ($\leq 140\%$ of calculated loss)								
Summer Design Conditions													
Outdoor °F:	85°F (A)	From Manual J8 Table 1A or 1B	A heat pump was selected for comparing cooling and heating design and performance. Other types of equipment may be used.										
Indoor °F:	75°F	Manual J8 §3-6 defaults to 75°F	Outdoor Unit Model Number:	HP-030	Fictitious heat pump								
Entering Wet Bulb (EWB):	63°F (B)	Manual J8 §3-6 defaults to 63°F EWB ($\approx 75^\circ\text{F} / 50\% \text{RH}$)	Total Cooling Capacity ($\leq 115\%$)	28,400Btu/h (F)	These capacities are from manufacturer's performance data at the DESIGN CONDITIONS: 85°F ODT, 1,000CFM, and 63°F EWB								
Total Heat Gain	27,543Btu/h (G)	Determined by Manual J8 load calculation	Sensible Cooling Capacity (\approx Sensible Gain)	21,600Btu/h (G)									
Sensible Heat Gain	23,321Btu/h (G)		Latent Cooling Capacity (\approx Latent Gain)	6,800Btu/h (G)									
Latent Heat Gain	4,222Btu/h		Indoor Unit Model Number:	AH-030	Fictitious air handler								
Sensible Heat Ratio (SHR)	85% (C)	See formula below	Indoor Blower CFM (CFM in manufacturer's performance data at rated capacity-medium fan speed):	1,000 (D)	The actual equipment rated airflow, (medium fan speed optimal) should fall within target CFM, ($7\% - 15\%$)								
Design Air Flow	1,116 CFM (D)	The "TARGET" airflow, we look for equipment that operates in this range ($7\% - 10\%$), on <u>medium</u> fan speed	Btu/h Difference between Heat Pump Balance Point and Total Heat Loss	30,281 Btu/h (H)	This heat pump can only produce 20,700Btu/h at design conditions. More capacity is required. (Air Conditioners do not have a balance point.)								
$\text{SHR} = \frac{\text{Sensible Heat}}{\text{Total Heat Gain}} = \frac{23,321\text{Btu/h}}{27,543\text{Btu/h}} = 85\%$			$\text{CFM} = \frac{\text{Sensible Heat Gain}}{\text{Design Temp} \times 1.1} = \frac{23,321\text{ Btu/h}}{19 \times 1.1} = 1,116\text{ CFM}$										
<table border="1"> <thead> <tr> <th>SHR</th> <th>Recommended Temp. Design</th> </tr> </thead> <tbody> <tr> <td>Below 0.80</td> <td>21°F</td> </tr> <tr> <td>0.80 – 0.85</td> <td>19°F</td> </tr> <tr> <td>Above 0.85</td> <td>17°F</td> </tr> </tbody> </table>		SHR	Recommended Temp. Design	Below 0.80	21°F	0.80 – 0.85	19°F	Above 0.85	17°F		Auxiliary Heat (Circle): Electric Gas Oil		
SHR	Recommended Temp. Design												
Below 0.80	21°F												
0.80 – 0.85	19°F												
Above 0.85	17°F												
From Manual J8 Tables		From Manual J8 Load Calculation	From Equip. Performance Data										

ACCA Manual J Brochure, page 2

The order of this checklist follows Form J1 of ACCA Manual J8®.

#	KEY ITEM	CHECK	QUESTIONS TO ASK	CIRCLE ANSWER*		
1	DESIGN TEMPERATURES	✓ Indoor Design Temperatures	Is the indoor design temperature for <i>Heating</i> : per Local Code OR 70°F (21°C) at 30% RH?	YES	NO	----
			Is the indoor design temperature for <i>Cooling</i> : per Local Code OR 75°F (24°C) at 50% RH? [or 55% for humid climate, 45% for dry climate?]	YES	NO	----
		✓ Outdoor Design Temperatures	Is the outdoor design temperature per Table 1 of MJ8 or Local Code?	YES	NO	----
2	WINDOWS & GLASS DOORS	✓ U-values and SHGC values	Are the SHGC and U-values reasonable for the window types and frame constructions? (see Table 2 of MJ8)	YES	NO	----
		✓ Shading Adjustments	Have window shading (curtains, drapes, insect screens, tinting, etc.) adjustments been made?	YES	NO	----
		✓ Overhang Adjustments	Have roof overhang adjustments been made?	YES	NO	----
		✓ Total Area	Is the total area for the windows & glass doors roughly equal to the area shown on the drawing plans?	YES	NO	----
		✓ Exposure Directions	Do the exposure directions [North (N), North-East (NE), etc.] appear correct?	YES	NO	----
3	SKYLIGHTS	✓ U-values and SHGC values	Are the SHGC and U-values appropriate for the skylight types and frame constructions? (see Table 2 of MJ8)	YES	NO	N/A
		✓ Shading Adjustments	Have adjustments been made for drapes, tinting and reflective coatings?	YES	NO	N/A
		✓ Total Area	Is the total area for the skylights roughly equal to the area shown on the drawing plans?	YES	NO	N/A
		✓ Exposure Directions	Do the exposure directions [North (N), North-East (NE), etc.] appear correct?	YES	NO	N/A
4	DOORS WOOD, METAL	✓ None	-----	-----	-----	
5	WALLS ABOVE GRADE, BELOW GRADE	✓ Insulation	Are correct wall insulation R-values taken into account when the wall loads are calculated?	YES	NO	----
		✓ Total Area	Is the total area for the walls equal to the area shown on the drawing plans?	YES	NO	----
6	CEILINGS	✓ Insulation	Is correct ceiling insulation R-value taken into account when the ceiling load is calculated?	YES	NO	N/A
		✓ Radiant Barrier	If applicable, does the load calculation take credit for a radiant barrier?	YES	NO	N/A
		✓ Roof color and material	Is correct roof color and material taken into account when the ceiling load is calculated?	YES	NO	----
		✓ Total Area	Is the total area for the ceilings equal to the area shown on the drawing plans?	YES	NO	----
7	FLOORS	✓ Insulation	Is the floor insulation and type of construction representative of what is built/planned?	YES	NO	----
8	INFILTRATION	✓ Envelope Tightness	Is the listed envelope tightness (tight, semi-tight, average, semi-loose, loose) appropriate?	YES	NO	----
		✓ Above grade volume	Is the total above grade volume equal to what is shown on the drawing plans?	YES	NO	----
9	INTERNAL GAINS	✓ Appliances	Are the appliance gains 1200 Btuh, 2400 Btuh or a value recommended by MJ8?	YES	NO	----
		✓ Occupants	Is Maximum Number of Occupants = Number of Bedrooms + 1?	YES	NO	----
			- Is Btuh (sensible) = 230 x Number of Occupants? - Is Btuh (latent) = 200 x Number of Occupants?	YES	NO	----
10	DUCTS	✓ Duct Location	If located in an unconditioned space, are the ducts insulated (appropriate R-value)?	YES	NO	N/A
		✓ Duct Tightness	Is the duct tightness category 'average sealed' or higher (i.e. notably sealed, extremely sealed)?	YES	NO	----
11	VENTILATION	✓ Intermittent Fans	Are intermittent bathroom and kitchen fans <u>excluded</u> from the infiltration calculations?	YES	NO	N/A
		✓ Continuous Exhaust Fans	Are dedicated exhaust fans (continuous) <u>included</u> in the calculations?	YES	NO	N/A
		✓ Heat Recovery Equipment	Are the heat recovery equipment and/or a ventilating dehumidifier included in the calculations (if applicable)?	YES	NO	N/A

* Questions should be answered 'YES' (where applicable) to achieve representative load calculations.



Upcoming Courses Questions



More Information

- **1.5 AIA LU's Available**
- **1.5 ICC LU's Available**
 - Contact spburns@countyofsb.org for any questions regarding LUs
- **Coming to Your Inbox Soon!**
 - Slides, Recording, & Survey – Please Take It and Help Us Out!
- **Upcoming Courses**
 - 4/5 - **The Value of Becoming a Certified Energy Analyst**
 - 4/21 - **All About ADU's for Households**
 - 5/10 - **All Electric Construction Part 1: Heat Pumps For Heating and Cooling**





Thank you!

For more info:
3c-ren.org

For questions:
info@3c-ren.org



TRI-COUNTY REGIONAL ENERGY NETWORK
SAN LUIS OBISPO • SANTA BARBARA • VENTURA